



Smith Septic Systems

66 Smith Shore Road
Belhaven, NC 27810

Office: 252-964-4204 • Fax: 252-964-6940

Cell: 252-943-1947 • Cell: 252-945-8080


ORDER
NO.

Maria Hobbs

DATE 4-29-25

SOLD
TO

18 King Blount, Bath NC 27808

Could only Inspect  outlet end of tank due to debris pile being on Inlet end of tank. Tank appeared water tight and had a PVC Tee w/Filter in it.
Dist Box was in good condition & had Dial-A-Flows in place.
Marked 4 corners of Drain field w/white flags.
Total \$450