

**Environmental Health
Pitt County Government
Backlog Permit File Scanning Separator Page
Template**

«Teyon_Wilson»

2/2/2022

For Barcode Fields, use underscore (_) for spaces and include * before and after entry. Exp: *01732*

Permit #:«



»

* W L S 1 9 8 7 - 0 0 1 4 9 2 *

PITT COUNTY HEALTH DEPARTMENT

1825 West Fifth Street
Greenville, North Carolina 27834

New Existing _____ Repair _____

Permit No. 1492-87-E

CERTIFICATE OF COMPLETION (COMPLIANCE)

Ground Absorption Sewage Disposal System (Septic Tanks)
N. C. General Statutes, Chapter 130A-Article 11

Sketch of Layout

Date 5-9-88

Owner Ralph C. Davenport, Jr.

Address ~~Davenport~~, lot #1 Emerald Chase S/D

Type of Use: Residence House # Bedrooms 3

Other _____ # Users _____

Tank: Capacity 1000 Mfg. AAA Serial # STR-AAA

Distance From House 18'

Drain Lines: Sq. Ft. 1200 # Lines 4 Width 36"


Depth of Surface 12"

Drainage: Required _____ Completed _____

Water Supply Bell Arthur

Installed by AAA

Inspected by Charles J. Lehmann
Sanitarian



Suitable
 Provisionally Suitable
Unsuitable

PITT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1825 West Sixth Street
Greenville, N.C. 27834 - Phone: 752-4141

Existing _____
New
Repair _____

APPLICATION

PN 45649

Article 11 of Chapter 130A of The General Statutes of North Carolina

Date Received 9-21-87
Owner Ralph C. Davenport Jr.
Address Rt 1 Box 64
Subdivision Name ~~Davenport~~ Emerald Chase 510 City Wentworthville
Directions 1253 Pocosin Rd Lot No. 1 Zip 27589
Block No. _____

In Reply Please Refer To:
Permit Number 1492-87
Phone 756-1339

Land Use house
Plat Required: Yes _____ No _____ Bedrooms 3 Water Supply Bell Arthur
*** This is an official document. Please retain with other valuable papers.

Ralph Davenport Jr.
Owner's Signature or Agent

IMPROVEMENT PERMIT

Site Classification Information:
Topography S Soil Texture PS
Soil Structure PS Soil Depth 5
Restrictive Horizon: S
Soil Drainage: Internal PS External SS
Soil Permeability _____ Estimated Flow 360
Other _____
Septic Tank Capacity 1000
Nitrification Square Footage 1200
Land Requirements _____

Layout Sketch
See attached Plot Plan.
Front

Comments Keep the rock in the lines 10" from the original soil surface. Landscaping the area over the septic tank system so that all surface water will run off.

Issued 11-9-87 By Charles J. Lehmann
Sanitarian

Approved 5-10-88 By Charles J. Lehmann
Septic Tank Approval
Sanitarian

Owner's Copy
5 MONTHS
Yellow - Health Department Copy
Pink - Building Inspector's Copy

Scanned of Attached

