

Nash County Environmental Health

On-Site Wastewater Permit
120 W. Washington Street, Nashville, NC 27856
252-459-9829



Permit Number: E-24-1155 Parcel ID: 356708 TOWNSHIP: Castalia
PIN: 287400117720 Owner: Tim Matthews
Applicant: Tim Matthews
Company: East Coast Timberland, Inc.

Subdivision: Culpepper Landing Sect: Ph: Lot: Phase One, Lot 6
Address of Property: 7218 RACE TRACK RD CASTALIA, NC 27816
Design Specifications: Authorized On-Site Wastewater Non-Residential Use:
Evaluator (AOWE a2)
Design Flow: 360 LTAR: .275 Trench Length: 340X3
Size Tank: 1000 Pump Tank: Grease Trap:
Type System: 25% Reduction Max Trench Depth: 12 Bedrooms: 3
Max Occupants: 6
Additional Inspections Required: Installer: John Alfred Tyson (5180)

This permit is valid for 5 years from Improvement Permit date.

Conditions: Do not drive, park, build, pave or concrete over any part of the system or repair. Site alterations or variations from the site plan may void permit and/or make the site unsuitable. If a pump system is required, a pressure manifold shall be used. Approved

Improvement Permit: **September 10, 2024** Authorized State Agent (Digitally Signed By): **ERIC CUTHRELL, REHS**
Construction Authorization: **September 10, 2024** Authorized State Agent (Digitally Signed By): **ERIC CUTHRELL, REHS**
Operation Permit: **March 12, 2025** Authorized State Agent (Digitally Signed By): **Eric Griffin REHS**