

PENDER COUNTY HEALTH DEPARTMENT

P. O. BOX 1209 BURGAW, N. C. 28425

(SEPTIC TANK) CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G.S. Chapter 190 - Article 19C)

OWNER OR CONTRACTOR Acavage Broker DATE 6-16-88 PERMIT NO. 444319

LOCATION 210 - 1002

SUBDIVISION NAME Wood Cliff LOT NO. 30 SECTION OR BLOCK NO. 1002

HOUSE MOBILE HOME BUSINESS

NUMBER OF BEDROOMS 3

GARBAGE DISPOSAL UNIT YES NO

AUTO. DISHWASHER YES NO

AUTO. WASH. MACHINE YES NO

SITE SUITABLE YES NO

SIZE OF TANK 900 GAL

NITRIFICATION FIELD 600 SQ. FT.

NUMBER OF LINES 3 lines at 67'

IMPROVEMENTS PERMIT BY Pamela C Overstreet

LOT AREA .38 acres

REMARKS 18" finish bottoms, 100' from all wells. 10' from property lines 5' from building foundation

INSTALLED BY _____

CERTIFICATE OF COMPLETION BY Pamela C Overstreet DATE 7-13-88

Construction must comply with all other applicable State and local regulations.
This permit does not constitute a warranty or guarantee and is void after 36 months.

