

DUBLIN COUNTY HEALTH DEPARTMENT

IMPROVEMENTS PERMIT, OPERATION PERMIT AND AUTHORIZATION FOR WASTE WATER CONTRUCTION
TELEPHONE: 296-2126

OWNER/OCCUPANT THOMPSON, ROLAND L
ADDRESS

DATE 07/14/2004
PERMIT NO. 18845

PD BOX 58
BEULAVILLE NC 285180058 PHONE NUMBER: 910-298-5688
ACCOUNT NUMBER: 8747300 TYPE OF SYSTEM: 2

REMARKS: CONVENTIONAL SYSTEM ONLY WITH TRENCHES 3' WIDE, UNLESS
AUTHORIZATION FOR OTHER TYPE SYSTEM IS OBTAINED

LOCATION HWY 41--LT ON DURWOOD EVANS RD--APPRX .50 MI LT ON QUIET
WATERS ESTATES--DOWN GRAVEL PATH AROUND CURVE ON RT

S. R. NU. 1964

SUBDIVISION NAME LOT NO. #12

PERMIT VAILID FOR 5 YEARS UNLESS SITE PLANS OR INTENDED USE CHANGE

HOUSE MOBILE HOME BUSINESS OTHER

NO. BEDROOMS/FLOW 3 360gpd

THIS PERMIT IN NO WAY

Soil Series I, II, III

GUARANTEES THE

Seasonal Wetness PROVISIONALLY SUITABLE

PERFORMANCE OR

Site Classification PROVISIONALLY SUITABLE

FUNCTIONING OF THIS

NEW/EXISTING NEW

SEWAGE DISPOSAL SYSTEM.

Size of Septic Tank 1000 Gal.

|

Nitrification Lines 600.00 sq. ft.

Authorization for Construction

No. of Lines 3

YES NO

Water Supply: Installed Yes Approved Yes
No X No

Date 07/26/2004 Valid Until 07/26/2009

SPECIALIST: DAVIN MADDEN

Site plan valid 5yrs

INSTALLED BY: MPC

Surveyed plat plan valid: Permanent

By: RONNIE KENNEDY

INSTALLATION INSPECTION

[Signature]

DATE 8-3-04

Pursuant to Article 11 of Chapter 130 of the General Statutes of North Carolina, "Sanitary Sewage Systems", and Laws and Rules for Sewage Treatment and Disposal Systems, Rules .1901 - .1968 of Title 15A Subchapter 18A of the, NCAC. Private Well must be sited in compliance with 15A NCAC.1950(a)1 100ft or (e)2 50ft

REMARKS: TYPE OF REPAIR: (Fill system 18"+) READ BELOW.

- * Install system along small ridge as shown.
- No deviation w/o authorization.
- Install lines no deeper than 24"
- Tank may be above natural grade.
- Repair area shown (will require 18"+ fill)
- Note 11ft setback.
- * System 600 Ft² (3x67'x3' lines)

