

MOORE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
OPERATION PERMIT

Finley, Larry & Dorothy
LRK 24015
143 Bluebird Ln
3 Bedroom septic

Owner: L. Finley Address: _____

Permit # _____ Receipt # _____ P.I.N. # _____

Installer: John Knight Telephone: _____

Address: _____

System Type: Concr Maximum Design Flow: 360 gpd (gallons/day)

Wastewater Characteristics: Residential

Septic Tank Capacity: 1000 (Gallons) Tank I.D. # 6/18/97 65939

Nitrification Line Dimensions: 3-6" x 3"

Effluent Distribution Device: D-B-1 Gravel Depth: 12"

Depth To: Top of Tanks: 2" (Inches) Trench Bottom 12-16" (Inches)

Diagram of Actual Installation: (Depict Property Boundaries, Structures, Driveways, Trees, Water Lines, Water Supplies, Etc.)


Scale: _____ Inch = _____ Feet.

Changes shown on front

Comments and Conditions: _____

Issued By: John Bed # of Attachments: _____
Date: 2/18/98

FINAL APPROVAL OF THIS SYSTEM SHALL INDICATE THAT THE SYSTEM HAS BEEN INSTALLED IN ACCORDANCE WITH APPLICABLE PERMIT CONDITIONS, LAWS AND RULES, BUT IN NO WAY SHOULD BE TAKEN AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORILY FOR ANY GIVEN TIME.



MOORE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION


P. O. BOX 279, CARTHAGE, N. C. 28327
PHONE: 910-947-2858 FAX: 910-947-5970

IMPROVEMENT PERMIT

Receipt # 14002 P.I.N. # 855404739778
Owner: Larry Finley
Address: 119 Bluebird Ln West End NC
Phone No. 215-0006
Exact Directions to Property: Left on Murdockville Rd from 73 Turn Left on Bluebird Trail then Right on Bluebird Ln
Lot Area: 2.1 AC Maximum Long-Term Soil Application Rate: .6
Daily Design Wastewater Flow Rate (From Application): 360 gpd
Septic Tank Capacity: 1000 (Gallons) Type Distribution Device: D.B.
Maximum Trench Depth (From Original Grade): 12-16" Pump Tank No Pump Tank Capacity N/A
Dimensions of Nitrification Lines: 3-67'x3'
System Type (Initial Installation): Conventional
Repair System Type (If Required): Conv.
Distance to Water Supplies: Wells, Springs, Etc. 2100' Lakes, Streams, Etc. 250'
Water Lines 210' Interceptor/Storm Drains N/A
Easements Required: Yes No X Tri-Party Agreement? Yes No X

NOTE: Should errors or omissions be noted in the drawings or specifications; or if there is doubt as to their meaning, this office should be contacted at once for an interpretation or clarification. All systems are subject to "Laws and Rules for Sewage Treatment and Disposal Systems, North Carolina General Statutes," Article 11 of Chapter 130A and North Carolina Administrative Code (T15A, 18A, 1901-1968).

System Layout (use applicant's plat or attach to permit) Scale 1 inch = 40 feet North []



-Keep 20' from Embankment
-IF you dont think you can keep lines shallow;
CALL me before you begin digging

OK JB 2/18/98

Comments:
Issued by: [Signature] Date: 2/11/98
Attachments:
This Permit is Valid unless the Site, Site Plan, Plat or Intended Use of the Property changes. -for 5 yrs

Authorization to Construct Wastewater System

Issued by: [Signature] Date: 2/11/98

This authorization is Necessary Prior to Obtaining a Building or Electrical Permit and Expires Sixty (60) Months From the Date Issued or Immediately if the Site, Site Plans or Intended Use of the Property Changes. Attachments: