

1301B-118

E HOP 2011-03292

ONSWLOW COUNTY  
HEALTH DEPT.

OPERATIONS PERMIT  
(GS 130A-337)

Permit No 6817  
System Type: II

Owner: The Farm S 10

Address: Lot 43 THE FARM S2 L43

Location: 106 MEETING HOUSE DR

SR # —

THIS DOES NOT CONSTITUTE A  
WARRANTY OR GUARANTEE.

Installed By: Frank Allen

Signed By: So Fzelle

Date: 5-16-01

FINAL PLOT/REMARKS

*4 bedroom - 480 gal per day*

ONSWLOW COUNTY  
HEALTH DEPT.

CONSTRUCTION AUTHORIZATION  
(GS 130A-336)

Permit No 6817

THIS AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION SHALL  
BE VALID FOR A PERIOD EQUAL TO THE PERIOD OF VALIDITY OF  
THE IMPROVEMENT PERMIT, NOT TO EXCEED 5 YEARS.

Fee: —

Owner: The Farm S 10

Address: Lot 43

Location: —

SR # —

System type/description: conventional LTAR .4 gpd/sq. ft.

Septic tank size: ≥ 1000 gallons

Nitrification area: 1200 sq. ft. 400 lin. ft.

No. of lines: 4 Line length: 100

Trench bottom depth: 18"

(SEE ATTACHED PAGES 1 - 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: Jason Sidney, R.S. Date: 1-20-00

ONSWLOW COUNTY  
HEALTH DEPT.

IMPROVEMENT PERMIT  
(GS 130A-336)

Permit No 6817

- Valid for 5 years from date of issuance
- Valid without expiration

Fee: \$ 100.00

Owner: The Farm S 10

Address: Lot 43

Location: —

SR # —

System type/description: — LTAR .4 gpd/sq. ft.

Facility/Daily design flow: 4 Bedroom Residence / 480 gpd

Water supply: On-site well — Comm. well — Public  Other —

(SEE ATTACHED PAGES 1 - 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: Jason Sidney, R.S. Date: 1-20-00

NOTE: Permit is subject to revocation if site plans or intended use change.

