


PLOT PLAN

Owner: HARVEST PLANTATION
 Address: LOT 4
 Location: HAW BRANCH RD

Additional Permit Conditions

1. Do not park or drive on any part of system or repair area
2. Nitrification trench aggregate shall be covered with straw, untreated paper or other approved materials prior to final cover/backfilling.
3. Do not install system under wet conditions.
4. Adhere to minimum set back requirements as stated in Rule .1950 and .1951 of NC Laws and Rules for Sewage Treatment and Disposal System (Article 11, G.S. Chapter 130A) unless otherwise indicated on this permit
5. Rock used in soil absorption systems shall be clean, washed gravel or crushed stone and graded or sized in accordance with size numbers 3, 4, 5, 57, or 6 of ASTM D-448 (standard sizes of coarse aggregate) which is hereby adopted by reference in accordance with G.S. 150 B-14 (c). Documentation of aggregate size shall be available upon request.
6. All pump tanks shall be tested for water tightness. Septic tanks may be subject to a water tightness test.
7. The septic tank is designed to receive sewage or wastewater under gravity flow. However, if a system subject to the N.C. Plumbing Code is used to pump raw sewage to the septic tank, the sewage shall be reduced to gravity/nonturbulent flow by approved means at the inlet of the septic tank.

1) INSTALL 4-60' CONVENTIONAL LINES
 18" T.B.



HAW BRANCH ROAD

10-10-19

APPROX SCALE 1"=40'
 10 NOVEMBER 2004