

11.1542/59



Wayne County (Environmental) – Improvements Permit

301 N. Herman Street, Box CC, Goldsboro, NC 27530

Phone:(919) 731-1174

Fax:

Final

Permit No: 21070106924

Appl. Dt.: 10/14/2021 **Exp. Dt.:** 10/14/2026

Status: ISSUED

Status Dt.: 3/6/2024

Owner Information

Name : J & N Developers Llc
Address : PO Box 658
 Princeton NC 27569
Phone(W) :
Phone(H) :
Phone(M) :

Property Information

PIN # : 113604542045
Address : 311 Fynloch Chase Dr
 Fremont NC 27830
Acreage : 0.57
Subdivision : Fynloch Chase
Lot # : 59
Directions : ALT Address: 0 Wellmyre Cut
Watershed district :

Site Details

System Classification : Type III
System Description : Other non-conventional trench sys
Line Length : 4(56x3)
Line Depth : 18.00
Nitrification Sq. Ft. : 900.00
Tank #1 : Septic Tank - 900.00
Tank #2 : Pump Tank - 900.00
Tank #3 :

Applicant Information

Name : J & N Developers Llc
Address : PO Box 658
 Princeton NC 27569
Phone(W) :
Phone(H) :
Phone(M) :

Occupant Information

Name : J & N Developers Llc

Water Details

System : New
Source : Public

Property Characteristics

Type of establishment : Residential dwelling units
Number of establishment : 3 Bedrooms
Septic GPD : 360
Basement : No
Basement Bath : No
Garbage Disposal : No
Multiple Dwelling Units : No
Property Notes : Max occupancy = 6 people

Permit Information

Septic System Requested :
System Description Requested :

Notes :

Inspections Conducted

Inspections	Signed Off/User ID	Date	Status	Reason
IP	EHBSAYERS	8/1/2023	OK/S	
ATC	EHBSAYERS	8/1/2023	OK/S	
OP	EHBSAYERS <i>[Signature]</i>	3/6/2024	OK/S	

Payment Information

Permit	Receipt No.	Fee	Ref#1	Amount	Status	Ref#2	Amount	Status	Ref#3	Amount	Status

WAYNE COUNTY

DEPARTMENT OF PUBLIC HEALTH




WAYNE COUNTY
NORTH CAROLINA

Operation Permit

PIN: 113604542045 Permit Number: 21070106924
 Subdivision or Road: Fynloch Chase Lot #: 59 Section: _____
 Specific System Installed: Chamber
 Septic Tank Size: 1,000 gallons Pump Tank Size: 1,000 gallons Trench Length: 6(50x3)
 System Type: III GPD: 360 Number of Bedrooms: 3 Maximum Number of Occupants 6
Types V and CI systems expire in 5 years in accordance with Table Va. Owner must contact health department 6 months prior to expiration for permit renewal.

J A N Developers, Llc Batten
 Owner's Name System Installer
✓ (PB) 2-22-24 ✓ (PB) 3/04 01-21-24 (AP)
 Tank Pump Paid
✓ (PB) 2-21-24 ✓ (PB) 3/04
 Lines Breakers



Brian [Signature] 03/02/24
 Authorized State Agent Date of Operation Permit Issuance

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961
- II. Monitoring: As required by Rule .1941
- III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed periodically from all compartments to ensure proper operation of system. Contents shall be pumped whenever solid levels are found to be more than 1/3 of the liquid depth of any compartment.