




Pasquotank County

IMPROVEMENT PERMIT

Owner: Prairie Dog, LLC
Owner Address: PO Box 2891
Owner Address(2): Kitty Hawk, NC 27949
Owner Phone #:
Property Address: Lot 32 Northeast Landing
Property Address(2): 102 Tideland Dr
PIN: 34179
Record #
Establishment Type: 4 BR Home
Type of Well: Public
Design Flow (GPD): 480

Initial Site
Wastewater System: Alternative
Long Term Acceptance Rate (GPD/SQFT): .32
Trench Width: 3 FT
Trench Spacing (OC): 10 FT
Trench Bottom From NGL: -6 IN
Mound Height: 12 IN
Septic Tank Volume: 1000 GAL



FILL AREA 60' X 120' WITH 12 INCHES OF SAND. Install tank so that top of lines are no more than 6 inches below top of fill. Excavate 5 trenches 100' long, 3' wide, on 10' centers, and 5.5' deep. Backfill with 4' of sand and install 12 inches of gravel and pipe. Keep system at least 10' from all property and water lines and 5' from any structure. Grade and landscape to promote proper runoff of surface water away from system.

Authorized Agent: [Signature] Date 3/9/2006

Approved: [Signature] Date: 6-8-06