

# CONSTRUCTION AUTHORIZATION



Lenoir County Health Department  
110 S Queen St.  
Kinston, NC 28501  
Phone: (252) 526-4248

For Office Use Only	
CDP File Number:	<u>452650 - 1</u>
PIN Number:	_____
Evaluated For:	<u>NEW</u>

PERMIT VALID UNTIL: 03/16/2031

Applicant: Gammon Construction  
 Address: 4787 Hwy 70 East  
 City: Princeton  
 State/ZIP: NC 28525  
 Phone #: \_\_\_\_\_

Property Owner: Gammon Construction  
 Address: 4787 Hwy 70 East  
 City: Princeton  
 State/ZIP: NC 28525  
 Phone #: \_\_\_\_\_

Address: 1721 Walnut Run Dr **Property Location & Site Information**  
 Road #: Deep Run, NC 28525 Subdivision: Walnut Run Phase: \_\_\_\_\_ Lot: 27  
 Township: \_\_\_\_\_ **Directions**  
 Structure: SINGLE FAMILY 1721 Walnut Run Dr  
 # of Bedrooms: 3  
 # of People: \_\_\_\_\_  
 Water Supply: PUBLIC

**System Specifications**

Usable Soil Depth: <u>42</u>	Minimum Trench Depth: _____ Inches
Saprolite System: <u>No</u>	Maximum Trench Depth: <u>24</u> Inches
Design Flow: <u>360</u>	Minimum Soil Cover: _____ Inches "natural Ground Level"
Soil Application Rate: <u>0.6</u>	Maximum Soil Cover: _____ Inches "natural Ground Level"
System Classification/Description: <u>Type IIa - Conventional System</u>	Distribution Type: <u>GRAVITY - PARALLEL (eq. d-box)</u>
Proposed System: <u>CONVENTIONAL</u>	Septic Tank: <u>1000</u> Gallons
Nitrification Field: <u>600</u> Sq. Ft.	Pump Required: <u>May be required</u>
No. Drain Lines: <u>4</u>	Pump Tank: _____ Gallons
Total Trench Length: <u>50ft.</u>	Grease Trap: _____ Gallons
Trench Spacing: <u>9Feet O.C.</u>	Septic Tank Installer Grade Level Required: _____
Trench Width: <u>36Inches</u>	
Aggregate Depth: <u>10inches</u>	

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

**Permit Conditions** Gravity flow shall be achieved or pump system shall be required.  
 System area and repair area shall be protected from vehicular traffic.

This Authorization for Wastewater System Construction shall be valid for a person equal to the period of validity of the Improvement Permit, not to exceed five years, and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization is found to have been incorrect, falsified or changed, or the site is altered, the permit or Construction Authorization shall become invalid, and may be suspended or revoked (per rule .0204(k)(1)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting and repair (per rule .0301(a)).

Authorized State Agent: 3489 - Brewer, Scott Date of Issue: 03/16/2026  
 Authorized State Agent Signature: Scott Brewer  
 Owner/Applicant Signature: \_\_\_\_\_