

Permit # R7627


**Environmental Health Section
Beaufort County Health Department
220 N. Market St.
Washington, North Carolina 27889
(252) 946-6048
Fax (252) 946-2074**

- New Construction
- Repair
- Existing System

IMPROVEMENTS PERMIT

Improvements permits are subject to revocation if the site plans or intended use changes or site alterations occur.

Date: 8-1-01
 Owner: Jennette & Antonio C. Luffo Phone: 975-6050
 Address: 105 Harbor Drive Washington, N.C. 27889
 Subdivision: Ridgewood Lot Number: 5
 State Road Number: 0FF1300 Directions: _____
 10-DIGIT PIN 5694-83-9106
 Property Size: 191'x186' Type Structure: House
 No. Bedrooms: 4 No. People: 3
 Water Supply: private / community (Maintain minimum 5-10 feet separation from any part of septic system and repair area.)
 Classification: Suitable Provisionally Suitable PS with fill
 Additional Drainage: landscape system area to shed surface water
 Seasonal Wetness Condition: _____ Soil Type: II
 Septic Tank: existing gal. Pump Tank: _____ gal.
 Nitrification Field: 540 square feet
 Trench Depth: shallow as possible Fill Depth: _____
 Comments: Add 3 lines - 3'x60' concrete and rock trenches for repairs. Place soil cloth over rock observe all proper setbacks. Call Environmental Health if questions.



Additional for all systems: Landscape system area for surface water runoff and grass. Do not place drive or any building over the system area or repair area. Observe all proper setbacks (10 NCAC 10A .1950). Do not work soil or install system in wet conditions. This permit must be on site during installation and inspection.

Environmental Health Specialist: [Signature] Date: 8-1-01

White — Owner/Contractor Yellow — Health Department Pink — Building Inspections