

# Environmental Health PENDER COUNTY, North Carolina

P. O. Box 1209  
Burgaw, NC 28425

Environmental Health  
910-259-1233



## EXISTING SEPTIC APPROVAL

<u>Zoning Determination</u>	<u>Existing Septic Approval</u>	Permit# : 162605	Fee : 75.00
BS	MC	Issued Date : 09142016	Code Violation:
9/13/16	9/22/16	Issued By : AB31	GEO PIN # : 42031024630000
		EH - File # : ESA16-127H	
		EHS ASSIGNED MC	

Permitted Use

Residential Addition - Deck

Description of Work

Residential Addition - Deck 8x10 connected to the rear of existing home

Applicant: HINRICHS GARY  
 OLDE POINT RD 151  
 HAMPSTEAD NC  
Relationship of Applicant to Owner :

Work Phone: 9105205838  
 Home Phone:  
 Fax :

Owner : KELLSWORTH LLC.  
 BATTERY RD 204  
 HAMPSTEAD NC

Work Phone:  
 Home Phone:  
 Fax :

**SITE ADDRESS :** 151 OLDE POINT RD  
 Subdivision : OLDE POINT  
 Section/Block : 1 Lot: 84 Deed Book/Page:  
 Township : TOPSAIL Plat Bk. & Page #:

WATER SUPPLY : SEWER SERVICE

Directions to Site:

151 Olde Point Rd, Hampstead NC

Requirements

STRUCTURE TYPE (MH, HOUSE, COMMERCIAL, OTHER-EXPLAIN) - KELLSWORTH LLC  
 ORIGINAL SYSTEM OWNER - /  
 DATE INSTALLED - /  
 ORIGINAL SYSTEM RECORD TANK GALLONS - /  
 ORIGINAL SYSTEM RECORD DRAIN FIELD SQ/FT - /  
 ORIGINAL RESIDENCE USE # OF BEDROOMS - /  
 CAPACITY APPROVED (# PERSONS, SEATS, ETC.) - \  
 SYSTEM LOCATION (FRONT OR BACK) - /  
 WELL LOCATION (FRONT, BACK, LEFT OR RIGHT) - /  
 APPLICATION TYPE (REPAIR, MH RELOCATE, BLDG. ADD, OR OTHER) - BLDG ADD  
 ISSUE RESIDENCE USE # OF BEDROOMS - /

Conditions

At the time of inspection no visible signs of malfunction were evident. However, since this is a subsurface sewage disposal system, it is impossible for this office to determine if any unauthorized modifications or misuse has occurred.

No warranty or guarantee is implied or expressed and future performance of this system is not assured by the Pender County Health Department.

Failing to maintain a properly operating septic tank system is considered a public health hazard and a violation of North Carolina State Laws and Rules Governing Sanitary Sewage Collection (Article 11 NC General Status Chapter 130A). Should the system malfunction or fail in the future, it shall be the responsibility of the owner to apply for a Permit for the repair of the system.

Dwelling shall be located a minimum of five (5) ft. from any part of septic system and repair area.

Permit valid for twelve (12) months from date of issuance


Signed: Melanie Campen Title: REHS Date: 9/22/16

Application/ Permit- Reconnection/ Change of Use/ Additional Structure

Note: Any reconnection, change of use, building addition or accessory structure or permanent foundation must receive approval from the Pender County Health Department.

OLDE POINT RD

Site Plan prepared  
by: *[Signature]*  
Approved by: *[Signature]*  
Date: *[Signature]*  
Permit # *[Signature]*



\* Repair \*

SYSTEM TYPE II

PENDER COUNTY HEALTH DEPARTMENT

MAP # \_\_\_\_\_

PAGE 1 OF 2

P.O. BOX 1209, BURGAW, NC 28425

PHONE: 910/259-1233

RECORD # \_\_\_\_\_

IMPROVEMENT PERMIT / CONSTRUCTION AUTHORIZATION

OPERATION PERMIT

Repair

OWNER / AGENT Lorenzo Smith DATE 1-6-06 PERMIT# 101127

ADDRESS 151 Oldo Point Road PHONE 617-3491

SITE LOCATION Hwy 17 N, right on ~~Oldo Point~~ <sup>Country Club</sup> Road, right on Oldo Point Road, lot on left.

SUBDIVISION Oldo Point LOT# 84 SECTION / BLOCK \_\_\_\_\_

HOUSE  MOBILE HOME  { # Bdrm. } 3 BUSINESS  { # EMPLOYEES/MEMBERS/SEATS } \_\_\_\_\_

WATER SUPPLY: PUBLIC  WELL  OTHER \_\_\_\_\_ DESIGNATED WETLANDS: YES  NO

BASEMENT/LOWER LEVEL PLUMBING YES  NO  SYSTEM MINIMUM REVIEW FREQUENCY N/A

DAILY DESIGN FLOW 360 gpd DOMESTIC WASTEWATER  INDUSTRIAL WASTEWATER

LTAR .6 gpd/ft<sup>2</sup> TANK SIZE Existing Gallons NITRIFICATION FIELD 600 Square Feet

NUMBER OF LINES 3 LENGTH 67 Feet DEPTH As shallow Inches WITH 3 Feet

BED SYSTEM SIZE N/A X \_\_\_\_\_ as possible with existing tank.

\*\*\*\*\*IF GARBAGE DISPOSAL UNIT IS TO BE USED AN EFFLUENT FILTER SHALL BE INSTALLED\*\*\*\*\*

SEE LAYOUT OR ATTACHED PLOT PLAN

NO CHANGE IN SEPTIC SYSTEM OR ITS LOCATION WITHOUT PRIOR APPROVAL FROM THE PENDER COUNTY HEALTH DEPARTMENT.

THIS PERMIT IS SUBJECT TO REVOCATION IF THE SITE PLAN, PLAT OR INTENDED USE OF THIS SITE CHANGES.

G.S. 130A-335 (f)

\*\*\*\*\*

MINIMUM HORIZONTAL SEPARATION OF SEPTIC SYSTEM {See Section .1950 a-c}

5 YEAR IMPROVEMENT PERMIT : James Teachey, ES ISSUE DATE 1-6-06

IMPROVEMENT PERMIT, NO EXPIRATION DATE: N/A ISSUE DATE \_\_\_\_\_

CONDITIONS / ADDITIONAL INFORMATION: \_\_\_\_\_

\* Check the Effluent Filter and D-box for clogs prior to installation of any new drain lines.

\* Pump Tank and check condition of the existing Tank. If it is damaged or in poor condition, install a new 1000 gallon tank.

\* Install 3 lines at 67' or shown on Plot Plan if filter and D-box is not the problem.

CONSTRUCTION AUTHORIZATION: James Teachey, ES ISSUE DATE 1-6-06  
VALID FOR 5 YEARS FROM THE DATE OF ISSUANCE OF IMPROVEMENT PERMIT.

OPERATION PERMIT : \_\_\_\_\_ ISSUE DATE \_\_\_\_\_


INSTALLER \_\_\_\_\_

THIS PERMIT DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE AND SATISFACTORY PERFORMANCE IS NOT ASSURED BY THE PENDER COUNTY HEALTH DEPARTMENT.

THE SITE IS SUBJECT TO APPROVAL BY OTHER PUBLIC AGENCIES. .1937 (b) (1) (C)  
PCHD/EH-3 Rev. 2-98

# PLOT PLAN

PENDER COUNTY HEALTH DEPT.  
ENVIRONMENTAL HEALTH SECTION  
P. O. BOX 1209  
BURGAW, NC 28423  
PERMIT # 101/27  
PAGE 2 OF 2  
*Jamun Teasley, PE* 1-6-06  
SIGNATURE DATE



\* Install 3 new lines at 67' x 3' wide between the existing drain lines.