

DUPLIN COUNTY HEALTH DEPARTMENT

2:30

IMPROVEMENTS PERMIT, OPERATION PERMIT AND AUTHORIZATION FOR WASTE WATER CONSTRUCTION
TELEPHONE: 296-2126

DATE 02/07/94
PERMIT NO. 5100

OWNER/OCCUPANT MILLER, RONNIE G. & WIFE
ADDRESS BARBARA
205 N FRISCO ST
WARSAW NC 283982015
ACCOUNT NUMBER: 5981508

REMARKS

LOCATION GROVE CREEK GO ACROSS POND AT EAST END, FIRST LOT ON LEFT

S.R.NO. 24
SUBDIVISION NAME PIN NO.

PERMIT VALID UNLESS SITE PLANS OR INTENDED USE CHANGE

HOUSE [X] MOBILE HOME [] BUSINESS [] OTHER []

NO. BEDROOMS/FLOW 4
Soil Series SANDY CLAY LOAM
Seasonal Wetness SUITABLE
Site Classification PROVISIONALLY SUITABLE
NEW/EXISTING NEW
Size of Septic Tank 1000 Gal.
Nitrification Lines 800.00 sq.ft.
No. of Lines 3-4
Water Supply: Installed Yes Approved Yes
No X No X

THIS PERMIT IN NO WAY
GUARANTEES THE
PERFORMANCE OR
FUNCTIONING OF THIS
SEWAGE DISPOSAL SYSTEM.

Authorization for Construction
YES [] NO []
Date Re-evaluate

SPECIALIST: JOHNNY SUMMERLIN
INSTALLED BY: Bra

By:

INSTALLATION INSPECTION [Signature] DATE 7/20/95

Pursuant to Article 11 of Chapter 130 of the General Statutes of North Carolina, "Sanitary Sewage Systems", and Sewage Collection, Treatment, and Disposal Systems Rules 10 NCAC 10A Section, 1900.

REMARKS: WELL SHOULD REMAIN 100' FROM SYSTEM; SEPTIC SYSTEM IN FRONT

