

SA Consulting LLC
PO Box 147
Perry, ME 04667
samaltvater@gmail.com
207-478-7105

November 11, 2023

To Whom It May Concern,

On November 7, 2023, I did a site evaluation on a portion of a lot adjacent to Wolf Cove Rd. in Eastbrook, Maine. The lot is approximately 9 -acres in size. A soil test pit was done and marked as TP 1 with a flagged wooden stake. (Coordinates 44°40'28.7" N, 68°13'33.3" W) The soil is a Profile 3, Condition D with 10" to the water table. The soil is suitable for a first-time septic system for a single-family home per the current Maine Subsurface Wastewater Disposal Rules. (10-144 CMR 241 dated August 3, 2015).

Thank you for choosing SA Consulting LLC. If you have any questions, please feel free to contact me at (207)478-7105.

Sincerely,



Samuel Altvater
Licensed Site Evaluator
#SE00429

Cc: file