






Legend	
Passes	
Fails EPA Primary	
Fails EPA Secondary	
Fails State Guideline	
Attention	

1  
2  
3

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**CLIENT SAMPLE ID:** 167 Twin Hill Road, Ellsworth, ME 04605  
**SAMPLE ID #:** 295-1851-1  
**CLIENT JOB #:**  
**OTHER SAMPLE INFO:** Drilled Well - Kitchen  
**SAMPLED BY:** PTHI  
**COLLECTION DATE/TIME:** 03/29/26 14:15

Test Description ( SM7500_Rn_B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Radon	4873	pCi/L	X		100	1	4000	TT - AUB		03/30/26 19:03

