

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: 400 East Side Road, Sorrento, ME 04677
SAMPLE ID #: 295-15415-1
CLIENT JOB #:
OTHER SAMPLE INFO: Drilled well/Bath tub
SAMPLED BY: Mary Della Torre
COLLECTION DATE/TIME: 08/03/26 12:02

Test Description (SM 4500 H+ B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
pH	7.83	SU	✓	HF	0.01	1	6.5-8.5	JR - AUB		08/04/26 10:00

Test Description (SM7500_Rn_B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Radon	6131	pCi/L	✗		100	1	4000	TT - AUB		08/04/26 17:43

Test Description (SM 2340B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Hardness as calcium carbonate	36.8	mg/L			0.25	1	No Limit	NH - DER		08/07/26 13:21

MEDIA TYPE:	Colilert-18									
Test Description (SM 9223B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Coliform, Total	Absent	/100mL	✓		1	1	Present	JR - AUB	08/04/26 11:45	08/05/26 08:30
Escherichia coli	Absent	/100mL	✓		1	1	Present	JR - AUB	08/04/26 11:45	08/05/26 08:30

Test Description (EPA 200.8)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Arsenic	0.0027	mg/L	✓		0.0010	1	0.01	NG - DER	08/05/26 08:00	08/05/26 17:28
Calcium*	11.4	mg/L			0.10	1	No Limit	NG - DER	08/05/26 08:00	08/05/26 17:28
Copper	0.030	mg/L	✓		0.0010	1	1.3	NG - DER	08/05/26 08:00	08/05/26 17:28
Iron*	<0.10	mg/L	✓		0.10	1	0.3	NG - DER	08/05/26 08:00	08/05/26 17:28
Magnesium*	2.04	mg/L			0.10	1	No Limit	NG - DER	08/05/26 08:00	08/05/26 17:28
Manganese	<0.0010	mg/L	✓		0.0010	1	0.05	NG - DER	08/05/26 08:00	08/05/26 17:28
Sodium*	31.5	mg/L			0.10	1	No Limit	NG - DER	08/05/26 08:00	08/05/26 17:28

Test Description (EPA 300.0)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Chloride	11.8	mg/L	✓		2.00	1	250	JR - AUB		08/04/26 17:26
Fluoride	2.04	mg/L	✓		0.20	1	4	JR - AUB		08/04/26 17:26
Nitrate as N	<0.20	mg/L	✓		0.20	1	10	TT - AUB		08/04/26 17:26
Nitrite as N	<0.20	mg/L	✓		0.20	1	1	TT - AUB		08/04/26 17:26

