

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: 29 Alder Lane, Tremont ME 04612
SAMPLE ID #: 295-8424-1
CLIENT JOB #:
OTHER SAMPLE INFO: Drilled Well - Bath
SAMPLED BY: Not Given
COLLECTION DATE/TIME: 06/01/26 14:00

Test Description (SM 4500 H+ B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
pH	6.96	SU	✓	HF	0.01	1	6.5-8.5	JR - AUB		06/02/26 15:25

Test Description (SM7500_Rn_B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Radon	1646	pCi/L	✓		100	1	4000	TT - AUB		06/02/26 23:11

Test Description (SM 2340B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Hardness as calcium carbonate	54.6	mg/L			0.25	1	No Limit	JR - DER		06/05/26 09:45

MEDIA TYPE: Colilert-18 Quanti-Tray

Test Description (SM 9223B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Coliform, Total	12	MPN/100mL	⚠		1	1	1	JR - AUB	06/02/26 14:20	06/03/26 09:00
Escherichia coli	<1	MPN/100mL	✓		1	1	1	JR - AUB	06/02/26 14:20	06/03/26 09:00

Test Description (EPA 200.8)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Arsenic	<0.0010	mg/L	✓		0.0010	1	0.01	NG - DER	06/03/26 08:55	06/03/26 18:56
Calcium*	16.9	mg/L			0.10	1	No Limit	NG - DER	06/03/26 08:55	06/03/26 18:56
Copper	<0.0010	mg/L	✓		0.0010	1	1	NG - DER	06/03/26 08:55	06/03/26 18:56
Iron*	<0.10	mg/L	✓		0.10	1	0.3	NG - DER	06/03/26 08:55	06/03/26 18:56
Lead	<0.0010	mg/L	✓		0.0010	1	0.015	NG - DER	06/03/26 08:55	06/03/26 18:56
Magnesium*	3.00	mg/L			0.10	1	No Limit	NG - DER	06/03/26 08:55	06/03/26 18:56
Manganese	0.014	mg/L	✓		0.0010	1	0.05	NG - DER	06/03/26 08:55	06/03/26 18:56
Sodium*	12.1	mg/L			0.10	1	No Limit	NG - DER	06/03/26 08:55	06/03/26 18:56
Uranium	2.03	ug/L	✓		1.00	1	30	NG - DER	06/03/26 08:55	06/03/26 18:56
Uranium, Calc*	1.36	pCi/L			0.670	1	No Limit	JR - DER		06/05/26 09:45

Test Description (EPA 300.0)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Chloride	14.3	mg/L	✓		2.00	1	250	JR - AUB		06/02/26 23:46
Fluoride	0.66	mg/L	✓		0.20	1	4	JR - AUB		06/02/26 23:46
Nitrate as N	<0.20	mg/L	✓		0.20	1	10	JR - AUB		06/02/26 23:46
Nitrite as N	<0.20	mg/L	✓		0.20	1	1	JR - AUB		06/02/26 23:46