

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: 42 Miles Road, Hancock ME 04640
SAMPLE ID #: 295-2664-1
CLIENT JOB #:
OTHER SAMPLE INFO: Drilled Well/Bath
SAMPLED BY: AWQ
COLLECTION DATE/TIME: 04/07/26 14:15

Test Description (SM7500_Rn_B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Radon	852	pCi/L	✓		100	1	4000	TT - AUB		04/08/26 17:12

Test Description (SM 2340B)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Hardness as calcium carbonate	<0.25	mg/L			0.25	1	No Limit	JR - DER		04/12/26 17:00

Test Description (EPA 200.8)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Arsenic	0.0012	mg/L	✓		0.0010	1	0.01	NG - DER	04/09/26 09:04	04/09/26 21:41
Calcium*	<0.10	mg/L			0.10	1	No Limit	NG - DER	04/09/26 09:04	04/09/26 21:41
Copper	0.0064	mg/L	✓		0.0010	1	1	NG - DER	04/09/26 09:04	04/09/26 21:41
Iron*	<0.10	mg/L	✓		0.10	1	0.3	NG - DER	04/09/26 09:04	04/09/26 21:41
Lead	<0.0010	mg/L	✓		0.0010	1	0.015	NG - DER	04/09/26 09:04	04/09/26 21:41
Magnesium*	<0.10	mg/L			0.10	1	No Limit	NG - DER	04/09/26 09:04	04/09/26 21:41
Manganese	<0.0010	mg/L	✓		0.0010	1	0.05	NG - DER	04/09/26 09:04	04/09/26 21:41
Sodium*	89.5	mg/L			0.10	1	No Limit	NG - DER	04/09/26 09:04	04/09/26 21:41
Uranium	2.50	ug/L	✓		1.00	1	30	NG - DER	04/09/26 09:04	04/09/26 21:41

Test Description (EPA 300.0)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Nitrate as N	<0.20	mg/L	✓		0.20	1	10	JR - AUB		04/08/26 12:40
Nitrite as N	<0.20	mg/L	✓		0.20	1	1	JR - AUB		04/08/26 12:40

MEDIA TYPE:	Colilert-18 Quanti-Tray									
Test Description (SM 9223B 20th ED)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Coliform, Total	<1	MPN/100mL	✓		1	1	1	JR - AUB	04/08/26 12:00	04/09/26 09:45
Escherichia coli	<1	MPN/100mL	✓		1	1	1	JR - AUB	04/08/26 12:00	04/09/26 09:45

Test Description (EPA 300.0 Rev 2.1)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Chloride	8.61	mg/L	✓		2.00	1	250	JR - AUB		04/08/26 12:40
Fluoride	0.36	mg/L	✓		0.20	1	4	JR - AUB		04/08/26 12:40

Test Description (SM 4500 H+B 19th E)	Results	Units	Pass/ Fail	DQ Flag	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
pH	7.60	SU	✓	HF	0.01	1	6.5 - 8.5	JR - AUB		04/08/26 13:46

