

F. Dimensional Requirements

The placement of principal and accessory structures on all lots shall meet or exceed the following minimum requirements:

Seventy-five (75) foot setback from the shoreline boundary of any salt water body;

Seventy-five (75) foot setback from the normal high-water line of tributary streams, freshwater body, or upland edge of a wetland;

One hundred (100) foot setback from the normal high-water line of a great pond;

4. Sixty (60) foot setback from the centerline of the traveled way of all roads open to the public;
5. Ten (10) foot setback from the centerline of any utility right-of-way;
6. Thirty (30) foot setback from all property lines.
7. The first floor elevation or openings of all buildings and structures including basements shall be elevated at least one foot above the elevation of the 100-year flood, the flood of record, or in the absence of these, the flood as defined by soil types identifiable as recent flood plain soils.

Provisions one (1), two (2), three (3), four (4) and seven (7) shall not apply to marine-related structures which require direct access to the water as an operational necessity. Provisions six (6) and seven (7) shall not apply to marine-related structures in the Fishery District.